



Government Of West Bengal
Office Of The Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services
Azad Hind Sarak, P.O.:- Ghurni, P.S.:- Kotwali, Pin :- 741103

Memo no.:FES/NAD/62/16.

Date: 19-06-2023

From:

Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services

To: Mr. Tanmoy Dey, Kiranprova English school

MOUZA-GANGNAPUR, VILL , P.S. and P.O.-GANGNAPUR, , NADIA, PIN-741238.

Sub: Issuance of Fire Safety Certificate for the existing construction of G+1 storied building under group Educational, in favour of name and style 'KIRANPROVA ENGLISH SCHOOL' formerly known as 'Kiranprova College' at the premises No. JL no. 175, KH no. LRS 3069, RS Plot no. 176, LRS 258,261 Mouza- Gangnapur, Vill, P.S. and P.O.-Gangnapur, Dist. Nadia, PIN-741238, West Bengal.

This is in reference to your application no. 0125189238700317 dated 09-06-2023 regarding the Issuance of Fire Safety Certificate for the existing construction of G+1 storied building under group Educational, in favour of name and style 'KIRANPROVA ENGLISH SCHOOL' formerly known as 'Kiranprova College' at the premises No. JL no. 175, KH no. LRS 3069, RS Plot no. 176, LRS 258,261 Mouza- Gangnapur, Vill, P.S. and P.O.-Gangnapur, Dist. Nadia, PIN-741238, West Bengal.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. One Stand by Fire Pump should be arranged with the down comer system within one month.
2. Driveway must be free from any type of obstruction for easy movement of fire appliances.
No parking will be allowed on the drive way.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be maintained strictly.
4. Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
5. A fire control room including a closed circuit TV system will have to be maintained which observe all floor of the building.
6. The notice of fire fighting and evacuation plan from the building shall be prepared and displayed at all suitable places of the building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.

8. Mock Fire practice and evacuation drill shall be performed periodically with participation of all Teaching, Non- Teaching employees and students of the building.
9. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
10. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
11. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
12. Adequate nos. of Fire Safety Directional Signage's Board and Assembly Point shall be prepared and be displayed at all appropriate places of the building.
13. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
14. Directional sign of escape route shall be displayed prominently.
15. This Fire Safety certificate is valid for three years and has to be renewed every three years from the date of issue of this letter.
- Any deviation and changes the nature of the use of the building in respect of submitted plan drawing, without obtaining prior permission from the office, the FSC shall be treated cancelled.

Signature valid

Digitally Signed
Name: SUBRAT
Date: 19-Jun-2023
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services